

**ELIZABETH CITY – PASQUOTANK - CAMDEN  
FIRE MARSHAL'S OFFICE  
PLANS REVIEW  
FIRE PROTECTION SIGNALING SYSTEM**

**Comply with all items below:**

- Systems must comply with the North Carolina State Building Code, North Carolina State Fire Code, National Electrical Code, and applicable NFPA Code and Standards.
- A permit shall be obtained from the Fire Marshal's Office.
- Plans shall be submitted to the Fire Marshal's Office for review and approval – a minimum of two weeks prior to the inception of the project.
- Wiring shall be approved for fire alarm use.
- Wiring shall be secured and protected according to the National Electric Code.
- Alarm shall be audible throughout the building.
- Strobes shall be visible throughout for the hearing impaired in accordance with the North Carolina Accessibility Code.
- Control panel shall be placed where it is visible and accessible and where a responsible party will be alerted to any trouble signal as well as alarm. Remote annunciators may be required by the code official.
- All detectors, manual pulls, horns, strobes, the control panel, and other component parts shall be compatible with the U.L. Listing.
- Submit certification of compliance to the Fire Marshal's Office upon job completion.
- A Fire Official shall witness the final testing. 100 % testing of appliances will be performed. Testing of smoke detectors to include duct detectors will be performed using real smoke provided by the contractor.